

November 9, 2010

DESIGN HOMES, INC.
KURT SMITH
600 N MARQUETTE RD
PO BOX 239
PRAIRIE DU CHIEN WI 53821

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: DESIGN HOMES, INC.
Product Name: PLUMBING DETAIL #2
Model Number(s): P-2
Product File No: 20100462

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2016.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on April 25, 2010 under product file number 20060092.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060092.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov